

PROUDLINE FIRE PROTECTION SERVICES LTD.



4211 Roper Rd.
Edmonton AB
T6B 3S5

Phone: (780) 490-7602
Fax: (780) 490-7605
E-mail: office@proudline.ca
Web: www.proudline.ca

A record of the monthly inspection is to be kept reflecting the date inspected initials of the person performing the inspection and any corrections required. If any discrepancies are noted while making this inspection, contact PROUDLINE FIRE PROTECTION immediately. Every six months a certified technician must complete an official inspection.

Procedure	Date				
1) Inspect all system components, agent distribution pipe, and conduit runs for physical damage and/or displacement.					
2) Inspect all nozzles to see if protective caps (if applicable) are in place. Check for possible obstructions to the discharge of the dry chemical.					
3) Inspect all detectors (Fusible-links and Thermo-bulbs) for contamination. If contamination is found contact for service.					
4) Inspect each Cylinder and Valve Assembly. The pointer on the pressure gauge should be in the green range. The cylinder should not show evidence of corrosion or damage.					
5) Ensure manual pull stations are unobstructed, in clear view and labeled for intended use.					
6) Ensure all tamper seals are intact and the system is in a ready condition.					
7) Verify the inspection tag or certificate is in place and current.					
8) Ensure the Universal Control Head is tightly bolted. The Cam/Flag assembly on the Control Head indicator should be in the 'SET' position. The safety pin and seal wire on the manual release handle should be in place.					
Initial					

